



ਉਪ ਮੰਡਲ ਇੰਜੀਨੀਅਰ, ਜਲ ਸਪਲਾਈ ਅਤੇ ਸੈਨੀਟੇਸ਼ਨ

ਉਪ ਮੰਡਲ, ਝੁਨੀਰ ਐਟ ਮਾਨਸਾ

Website:-www.pbdwss.gov.in., E-Mail:-subdivisionjhuniratmansa@gmail.com

Letter No:- 497

Date:- 29/5/2023

Certificate regarding safe drinking water and sanitary condition

Certified that Shri Guru Nanak Dev Academy, Khiali Chehlanwali, Mansa Road, Jhunir, Distt Mansa, Punjab was visited and inspected by Sh. Rajnish Kumar, Junior Engineer and found that Shri Guru Nanak Dev Academy Khiali Chehlanwali Mansa Road Jhunir, Distt Mansa Punjab has safe drinking facilities as per report No. DWTL/MNS/2223/00188 dated:-14/03/2023 by District Water Testing Laboratory Mansa and maintaining the hygienic sanitation condition in the school campus.


Principal
Shri Guru Nanak Dev Academy
C.B.S.E. Aff. No. 1630682
Jhunir (Mansa) Pb.


Sub Divisional Engineer
W/S & Sanitation Sub Division
Jhunir At Mansa

DISTRICT WATER TESTING LABORATORY, MANSA
Water Supply and Sanitation division no. 1 Complex, Jawaharke, Mansa, District Mansa
dwtlmsa@gmail.com

TEST REPORT

Name & Address of Customer : SHRI GURU NANAK DEV ACADEMY SHRI GURU NANAK DEV ACADEMY, MANSA ROAD, JHUNIR, DISTRICT MASNA	Customer Reference No.	No : 133 Dated : 22/02/2023
	Sample Submitted by	SH. GIAN AMRIT SINGH
	Date of Sample Receipt	22/02/2023
	Analysis Starting Date	06/03/2023
	Analysis completion Date	07/03/2023

Discipline : Chemical Testing	Group: Water
ULR No.: TC000123000000047F	Sample Type : Water
Test Report No.: DWTL/MNS/2223/00188	Date of Issue : 14/03/2023
Registration no.: DWTL/MNS/REG2223/00664	Condition of Sample : Unsealed
Source : Not Mentioned	Quantity/Type of Bottle: 500 ml / Transparent Plastic Bottle
Scheme : Not Mentioned	Location/Depth : SHRI GURU NANAK DEV ACADEMY,MANSA ROAD, JHUNIR DISTRICT MASNA / NA
Village : Not Mentioned	Habitation : Not Mentioned
Block: Not Mentioned	District : Mansa
Latitude : Not Mentioned	Longitude: Not Mentioned

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	Colour	3	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
2	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
3	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 1984) (RA 2017)
4	TDS	100	500	2000	mg/l	IS 3025 (Part 16-1984) Gravimetric Method
5	Alkalinity	56	200	600	mg/l	IS 3025 (Part 23-1986) Indicator Method
6	Hardness	44	200	600	mg/l	IS 3025 (Part 21- 2019) EDTA Method
7	Calcium	6	75	200	mg/l	IS 3025 (Part 40-1991) EDTA Titrimetric Method
8	Magnesium	7	30	100	mg/l	APHA (23rd Ed.2017) Method: 3500-Mg+2 B By Calculation Method
9	Chloride	32	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed), ND=Not Detected
5. * Value not available or test not performed for this parameter.



Ms. Komal Sharma
Quality Manager
Authorized Signatory
For, District Water Testing Laboratory, Mansa

----- End of the Test Report -----


Principal
Shri Guru Nanak Dev Academy
C.B.S.E. Aff. No. 163068
Jhunir (Mansa) Ph